

別紙 照明器具・点灯条件リスト

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間 日数	1日 当り
			台			
本館B2F	電気室	F42	8	1.0	245	1
		G41	9	1.0	245	1
	発電機室	F42P	8	1.0	245	1
	中央監視室	A42	7	1.0	245	11
		A42E	2	1.0	245	11
		A41	2	1.0	245	11
	廊下	A41	6	1.0	245	11
		機械室	F42	28	1.0	245
			E41	2	1.0	245
	熱源室	F42	9	1.0	245	1
	清掃員詰所	A42	2	0.3	245	11
		A42E	2	0.3	245	11
	用具入れ	D21	1	1.0	245	1
	書庫	D42	4	1.0	245	1
	湯沸室	D22	1	0.3	245	11
		M21	1	0.3	245	11
	便所	A41	1	0.5	245	11
		L21	1	0.5	245	11
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	EVホール	A42	1	1.0	245	11
		A42E	1	1.0	245	11
	倉庫(2)	G41	2	1.0	245	1
	倉庫(4)	D41	1	1.0	245	1
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	倉庫(5)	D41	1	1.0	245	1
	消火ポンプ室	F41P	2	1.0	245	1
EPS	J41	1	1.0	245	1	
本館B1F	女子更衣室	D42	6	0.5	245	11
	男子更衣室	D41	10	0.5	245	11
	倉庫(1)	D42	8	1.0	245	1
	廊下	A41	5	1.0	245	11
	倉庫	D42	2	1.0	245	1
		D42	2	0.5	245	11
		D42E	1	0.5	245	11
	印刷室	D42	2	0.5	245	11
		D42E	1	0.5	245	11
		D42E	2	0.5	245	11
	女子休憩室	D42	2	0.3	245	11
		L41	2	0.3	245	11
		L21	3	0.3	245	11
		f100	1	0.3	245	11
		D42E	1	0.3	245	11
	倉庫(2)	G41	3	1.0	245	1
	EPS	G41	1	1.0	245	1
脱衣室、浴室	K41W	1	1.0	245	1	
	D41W	1	1.0	245	1	
	L21	1	1.0	245	1	
便所	A22	1	0.5	245	11	

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数	1日当り
			台			
		T41	2	0.5	245	11
		b100	3	0.5	245	11
		E41	2	0.5	245	11
	議会書庫	D41	2	1.0	245	1
	湯沸室	M21	1	0.3	245	11
		D41	1	0.3	245	11
	EVホール	E41	4	1.0	245	11
		a27	4	1.0	245	11
	倉庫(3)	D41	1	1.0	245	1
	保管庫	D42	1	1.0	245	1
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	PS	G41	1	1.0	245	1
	倉庫(4)	D41	2	1.0	245	8
本館1F	食堂	E41	50	1.0	245	8
		E21	8	1.0	245	8
		a27	24	1.0	245	8
		d25	86	1.0	245	8
	機械室	F41	1	1.0	245	1
		G41	2	1.0	245	1
	休憩室	D42	1	0.3	245	8
		D42E	1	0.3	245	8
	厨房	D42W	4	1.0	245	8
		D42EW	2	1.0	245	8
				1.0	245	8
	パントリー	D42	2	1.0	245	8
		D42E	1	1.0	245	8
	事務室	Q42C	5	1.0	245	11
		Q42CE	3	1.0	245	11
		Q42	17	1.0	245	11
		Q42E	3	1.0	245	11
	風除室	a27	6	0.5	245	11
		a27s	4	0.5	245	11
	エントランス	a27	8	1.0	245	11
	事務室	Q42C	20	1.0	245	11
		Q42CE	8	1.0	245	11
		Q42	37	1.0	245	11
		Q42	60	1.0	245	11
		Q42E	15	1.0	245	11
	事務室	A42	14	1.0	245	11
		A42E	4	1.0	245	11
		A41	2	1.0	245	11
	収入役室	E41	20	1.0	245	11
		E41	1	1.0	245	11
		a100	6	1.0	245	11
	EVホール、エントランスホール	E41	22	1.0	245	11
		E42	9	1.0	245	11
		E41	8	1.0	245	11
		a27	4	1.0	245	11

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数	1日当り
			台			
		E21	2	1.0	245	11
	市民ロビー	E43	64	1.0	245	11
		E43	16	1.0	245	11
		a27	24	1.0	245	11
	風除室	A41	1	0.5	245	11
	廊下	A41	5	1.0	245	11
		A42	4	1.0	245	11
		A42E	2	1.0	245	11
	宿直室	i32	1	1.0	365	11
	警備員室	A42E	1	1.0	365	11
	休憩室	i32	1	0.3	245	11
	湯沸室	D41	2	0.3	245	11
		M21	1	0.3	245	11
	小会議室(1)	A42	3	0.7	245	11
		A42E	1	0.7	245	11
	CDコーナー、指定金融機関	A42	3	1.0	245	11
		A42E	1	1.0	245	11
		D41	2	1.0	245	11
	待合ロビー	Q42	47	1.0	245	11
		Q42E	14	1.0	245	11
	倉庫(1)	D42	4	1.0	245	1
	倉庫	D42	2	1.0	245	1
	議会階段	E41	12	1.0	90	8
		E21	1	1.0	90	8
	市民ホール	a27	19	1.0	245	9.5
	資料室	A42E	2	1.0	245	11
		A42	2	1.0	245	11
	情報センター	A42	4	1.0	245	11
		A42E	2	1.0	245	11
	風除室	a27	4	0.5	245	11
		a27s	2	0.5	245	11
	電話コーナー	f100	3	1.0	245	11
	自販機コーナー	A42	1	1.0	245	11
	風除室	a27	4	0.5	245	11
		a27s	2	0.5	245	11
	廊下	a27	3	1.0	245	11
	書庫(2)	D42	4	1.0	245	1
	多目的便所	A22	1	0.5	245	11
	相談室(2)	Q42E	1	0.7	245	11
	廊下	A41	2	1.0	245	11
	機械室	F42P	2	1.0	245	1
		F42	4	1.0	245	1
	湯沸室	D41	3	0.3	245	11
		M21	1	0.3	245	11
	便所	T41	2	0.5	245	11
		a27	3	0.5	245	11
		b100	3	0.5	245	11
		A22	1	0.5	245	11
	待合ロビー	Q42	5	1.0	245	11
		Q42E	3	1.0	245	11
	相談室(3)(4)(5)	A42E	3	0.7	245	11
		D41	1	0.7	245	11
	児童相談室	A42	2	0.7	245	11

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数	1日当り
			台			
		A42E	2	0.7	245	11
	小会議室(2)	A42	2	0.7	245	11
		A42E	2	0.7	245	11
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
本館2F	事務室	Q42	18	1.0	245	11
		Q42E	3	1.0	245	11
		Q42C	11	1.0	245	11
		Q42CE	4	1.0	245	11
	廊下	A42E	5	1.0	245	11
		A22E	4	1.0	245	11
	傍聴席、記者席	a27	37	1.0	90	8
	議場	P400S	16	1.0	90	8
		R400	50	1.0	90	8
	議場エントランス	E41	23	1.0	90	8
		E42	2	1.0	90	8
	委員会室	B46	12	1.0	90	8
		a100	9	1.0	90	8
	全員協議会室	E41	14	1.0	90	8
		E41	46	1.0	90	8
		E21	2	1.0	90	8
		a100	26	1.0	90	8
		p100	33	1.0	90	8
	議員控室	A42	40	1.0	90	8
		A42E	16	1.0	90	8
	議会事務局	A42	10	1.0	90	8
		A42E	2	1.0	90	8
	正副議長室	E41	20	1.0	90	8
		a100	14	1.0	90	8
		E41	2	1.0	90	8
	応接室	B46	4	1.0	90	8
		a100	8	1.0	90	8
	議員応接室1,2	B46	2	1.0	90	8
	談話室	B46	2	1.0	90	8
	議会ロビー、廊下	a27	44	1.0	90	8
	議会ラウンジ	E42	8	1.0	90	8
		a27	22	1.0	90	8
	中会議室	Q42	8	0.7	245	11
		Q42E	1	7.0	245	11
		Q42C	5	0.7	245	11
		Q41CE	1	0.7	245	11
	事務室	Q42	5	1.0	245	11
		Q42E	1	1.0	245	11
		Q42C	3	1.0	245	11
		Q42CE	1	1.0	245	11
	相談室(1)(2)(3)	A42	3	0.7	245	11
		A42E	3	0.7	245	11
	記者室	A42	5	1.0	90	8
		A42E	1	1.0	90	8

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数	1日当り
			台			
		A42C	3	1.0	90	8
		A42CE	1	1.0	90	8
	小会議室	A41	4	0.7	245	11
	湯沸室	D22	1	0.3	245	11
		M21	1	0.3	245	11
	機械室	F41	3	1.0	245	1
		F41P	1	1.0	245	1
	便所	a27	2	0.5	245	11
		b100	3	0.5	245	11
		T41	1	0.5	245	11
		T42	1	0.5	245	11
		E41	2	0.5	245	11
		l40	2	0.5	245	11
	EVホール	E41	16	1.0	245	11
		E21	6	1.0	245	11
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	市民ホール	E41	60	1.0	245	8
		R400	16	1.0	245	8
		E42	4	1.0	245	8
	議会休憩室	E41	9	1.0	90	8
	物入	l40	1	1.0	90	1
	踏込	a100	2	1.0	90	8
		f100	1	1.0	90	8
	廊下	a27	9	1.0	90	8
	議員図書室	A42	4	1.0	90	8
		A42E	2	1.0	90	8
	機械室	G41	2	1.0	90	1
		F41	2	1.0	90	1
	湯沸室	D41	2	1.0	90	8
		M21	1	1.0	90	8
	便所	a27	2	1.0	90	8
		b100	2	1.0	90	8
		E41	2	1.0	90	8
		T41	1	1.0	90	8
	便所	a27	3	1.0	90	8
		b100	3	1.0	90	8
		T41	2	1.0	90	8
		l40	1	1.0	90	8
	議場ロビー	E43	8	1.0	90	8
		E41	16	1.0	90	8
	モニター室	A42	1	1.0	90	1
		A42E	1	1.0	90	1
	機械室	F41P	2	1.0	90	1
		G41	1	1.0	90	1
	階段	a27	13	1.0	90	8
本館3F	市長室	E41	49	0.5	245	11
		E41	2	0.5	245	11
		a100	18	0.5	245	11

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数	1日当り
			台			
	秘書課事務室	A42	11	1.0	245	11
		A42E	2	1.0	245	11
		A42C	5	1.0	245	11
		A42CE	1	1.0	245	11
	応接室2	E21	24	0.5	245	11
		E41	2	0.5	245	11
		a100	8	0.5	245	11
	廊下	a27	21	1.0	245	11
	助役室1	E41	20	1.0	245	11
		E41	1	1.0	245	11
		a100	6	1.0	245	11
	応接室1	E21	24	0.5	245	11
		a100	6	0.5	245	11
	助役室2	E41	20	1.0	245	11
		E41	1	1.0	245	11
		a100	6	1.0	245	11
	庁議室	E21	52	0.7	245	11
		E41	28	0.7	245	11
	事務室	Q42C	10	1.0	245	11
		Q42	16	1.0	245	11
	事務室	Q42C	14	1.0	245	11
		Q42	20	1.0	245	11
	市長応接室	E41	6	0.5	245	11
		E42	8	0.5	245	11
		a100	10	0.5	245	11
	休憩室	C46	1	0.3	245	11
		a100	1	0.3	245	11
	クロゼット	a100	2	1.0	245	1
		E21	1	1.0	245	1
	機械室	E41P	2	1.0	245	1
		E41	2	1.0	245	1
	廊下	A42E	5	1.0	245	11
		A22	4	1.0	245	11
	湯沸室	M21	1	0.3	245	11
		D42	1	0.3	245	11
	更衣室	D42	1	0.3	245	11
	便所	a27	2	0.5	245	11
		b100	3	0.5	245	11
		T42	1	0.5	245	11
		T41	1	0.5	245	11
		l40	2	0.5	245	11
		E41	2	0.5	245	11
	更衣室	D42	2	0.3	245	11
	EVホール	E42	4	1.0	245	11
		E41	4	1.0	245	11
		E21	1	1.0	245	11
	多目的便所	A22	1	0.5	245	11
	湯沸室	a27	2	0.3	245	11
		M21	1	0.3	245	11
	機械室	F41P	2	1.0	245	1
		E41	2	1.0	245	1
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数	1日当り
			台			
		J22	1	1.0	365	24
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
本館4F	事務室	Q42	21	1.0	245	11
		Q42E	3	1.0	245	11
		Q42C	13	1.0	245	11
		Q42CE	3	1.0	245	11
	廊下	A42E	10	1.0	245	11
		A22E	4	1.0	245	11
	事務室	Q42C	25	1.0	245	11
		Q42CE	5	1.0	245	24
		Q42	40	1.0	245	11
		Q42E	5	1.0	245	11
	入札室	Q42	10	0.5	245	11
		Q42E	2	0.5	245	11
		Q42C	6	0.5	245	11
		Q42CE	2	0.5	245	11
	契約検査室	Q42	8	1.0	245	11
		Q42E	1	1.0	245	11
		Q42C	5	1.0	245	11
		Q42CE	1	1.0	245	11
	機械室	F41	3	1.0	245	1
		Q41	1	1.0	245	1
	便所	a27	2	0.5	245	11
		b100	3	0.5	245	11
		T42	1	0.5	245	11
		T41	1	0.5	245	11
		l40	2	0.5	245	11
		E41	2	0.5	245	11
	更衣室	D42	2	0.3	245	11
	EVホール	E42	4	0.5	245	11
		E41	4	0.5	245	11
		E21	1	0.5	245	11
	倉庫	D41	1	1.0	245	1
	湯沸室	D42	1	0.3	245	11
		M41	1	0.3	245	11
	機械室	F41	3	1.0	245	1
		Q41	1	1.0	245	1
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
本館5F	事務室	Q42	40	1.0	245	11
		Q42E	5	1.0	245	11
		Q42C	25	1.0	245	11
		Q42CE	5	1.0	245	11
	廊下	A42E	10	1.0	245	11
		A22	4	1.0	245	11
	事務室	Q42C	25	1.0	245	11
		Q42CE	5	1.0	245	11

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数	1日当り
			台			
		Q42	40	1.0	245	11
		Q42E	5	1.0	245	11
	機械室	F41P	3	1.0	245	1
		G41	1	1.0	245	1
	便所	a27	2	0.5	245	11
		b100	3	0.5	245	11
		T42	1	0.5	245	11
		T41	1	0.5	245	11
		l40	2	0.5	245	11
		E41	2	0.5	245	11
	コピー室	D42	2	0.7	245	11
	EVホール	E42	4	1.0	245	11
		E41	4	1.0	245	11
		E21	1	1.0	245	11
	倉庫	D41	1	1.0	245	1
	湯沸室	a27	2	0.3	245	11
		M21	1	0.3	245	11
	機械室	F41P	3	1.0	245	11
		G41	1	1.0	245	11
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
本館6F	事務室	Q42	40	1.0	245	11
		Q42E	5	1.0	245	11
		Q42C	25	1.0	245	11
		Q42CE	5	1.0	245	11
	廊下	A42E	10	1.0	245	11
		A22	4	1.0	245	11
	事務室	Q42C	25	1.0	245	11
		Q42CE	5	1.0	245	11
		Q42	40	1.0	245	11
		Q42E	5	1.0	245	11
	機械室	F41P	3	1.0	245	1
		G41	1	1.0	245	1
	便所	a27	2	0.5	245	11
		b100	3	0.5	245	11
		T42	1	0.5	245	11
		T41	1	0.5	245	11
		l40	2	0.5	245	11
		E41	2	0.5	245	11
	更衣室	D42	2	0.3	245	11
	EVホール	E42	4	0.5	245	11
		E41	4	0.5	245	11
		E21	1	0.5	245	11
	倉庫	D41	1	1.0	245	1
	湯沸室	a27	2	0.3	245	11
		M21	1	0.3	245	11
	機械室	F41P	3	1.0	245	1
		G41	1	1.0	245	1
	西階段	H41	1	1.0	365	24

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数	1日当り
			台			
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
本館7F	事務室2	Q42	35	1.0	245	11
		Q42E	4	1.0	245	11
		Q22	2	1.0	245	11
		Q22E	1	1.0	245	11
		Q42C	20	1.0	245	11
		Q42CE	4	1.0	245	11
	教育長室	B46	4	1.0	245	11
	廊下	A42E	10	1.0	245	11
		A22	4	1.0	245	11
	委員長室	B46	4	1.0	245	11
	事務室1、大会議室	Q42	23	0.7	245	11
		Q42E	4	0.7	245	11
		Q42C	14	0.7	245	11
		Q42CE	4	0.7	245	11
	委員会室	E41	28	1.0	245	11
		E21	56	1.0	245	11
	機械室	F41P	3	1.0	245	1
		G41	1	1.0	245	1
	便所	a27	2	0.5	245	11
		b100	3	0.5	245	11
		T42	1	0.5	245	11
		T41	1	0.5	245	11
		l40	2	0.5	245	11
		E41	2	0.5	245	11
	更衣室	D42	2	0.3	245	11
	EVホール	E42	4	1.0	245	11
		E41	4	1.0	245	11
		E21	1	1.0	245	11
	倉庫	D41	1	1.0	245	1
	湯沸室	a27	2	0.3	245	11
		M21	1	0.3	245	11
	機械室	F41P	3	1.0	245	1
		G41	1	1.0	245	1
	監査室	A42	5	1.0	245	11
		A42E	1	1.0	245	11
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
本館8F	特大会議室	E41	247	0.7	245	11
		a100	48	0.7	245	11
	談話コーナー	A42	14	0.7	245	11
		A42E	4	0.7	245	11
	和室休憩室1,2	E41	48	0.3	245	11
		E41	2	0.3	245	11
	参与室	A42	1	1.0	245	11

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数	1日当り
			台			
		A42E	1	1.0	245	11
		A42C	3	1.0	245	11
		A42CE	1	1.0	245	11
	事務室	A42	16	1.0	245	11
		A42E	3	1.0	245	11
		A42C	6	1.0	245	11
		A42CE	2	1.0	245	11
	廊下	A42E	5	1.0	245	11
		A22	4	1.0	245	11
	機械室	F41	3	1.0	245	1
		E41	1	1.0	245	1
	控室	A42	2	0.3	245	11
		A42E	1	0.3	245	11
	便所	a27	2	0.5	245	11
		b100	3	0.5	245	11
		T42	1	0.5	245	11
		T41	1	0.5	245	11
		l40	2	0.5	245	11
		E41	2	0.5	245	11
	EVホール	E41	20	0.5	245	11
		E21	2	0.5	245	11
	多目的便所	A22	1	0.5	245	11
	湯沸室	D42	1	0.3	245	11
		M21	1	0.3	245	11
	倉庫(2)	D41	2	1.0	245	1
	無線室	A42	2	1.0	245	1
		A42E	2	1.0	245	1
	電話交換室	A42E	2	1.0	245	11
		A42	1	1.0	245	11
	踏込	a100	4	1.0	245	11
		f100	2	1.0	245	11
	休養室(1)	A42	3	0.3	245	11
		A42E	1	0.3	245	11
	休養室(2)	A42	3	0.3	245	11
		A42E	1	0.3	245	11
	医務室	A42	2	1.0	245	11
		A42E	2	1.0	245	11
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
	東階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
		J22	1	1.0	365	24
本館PHF	機械室	F41	6	1.0	245	1
		G41	5	1.0	245	1
	西階段	H41	1	1.0	365	24
		J41	1	1.0	365	24
別館1F	資材倉庫	D42	12	1.0	245	1
	洗車スペース	E41	12	0.5	245	11
	倉庫(1)	E41	12	1.0	245	1
	廊下	A22B	3	1.0	245	11
	倉庫	E41	1	1.0	245	1
	ボイラー室	D41	2	1.0	245	1

階数	室名	器具		運転時間		
		記号	台数	稼働率	年間日数 日	1日当り h
			台			
	便所	D42	1	0.5	245	11
		L21	2	0.5	245	11
	ゴミ置き場	D42	2	1.0	245	1
	風除室	A42B	2	0.5	245	11
	運転手控室	D42	2	0.5	245	11
		D42B	2	0.5	245	11
		D41	1	0.5	245	11
	和室	i32	1	0.3	245	11
別館2F	会議室	A42	6	0.7	245	11
		A42B	6	0.7	245	11
	組合事務室	A42	4	1.0	245	11
		A42B	2	1.0	245	11
	談話室	A42	2	0.7	245	11
		A42B	1	0.7	245	11
	控室	D42	4	0.3	245	11
		D42B	2	0.3	245	11
	倉庫	D42	2	1.0	245	1
	脱衣室、浴室	D42W	3	1.0	245	1
	湯沸室	D41	1	0.3	245	11
		M21	1	0.3	245	11
	便所	D42	4	0.5	245	11
		L21	4	0.5	245	11
	印刷室	D42	1	1.0	245	11
		D42B	1	1.0	245	11
	倉庫	D42	2	1.0	245	1
	廊下	A22B	5	1.0	245	11
外構		ア-100w	3	1.0	365	15
		ウ-100wa	6	1.0	365	15
		ウ-100wb	9	1.0	365	15
		エ-102w	20	1.0	365	15
		オ-103wa	37	1.0	365	15
			3736			

※B46はリニューアルタイプ又は器具改造も可とする。